

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2015 and the monitoring period of June - September 2015**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-49603	15123217	697EPA138		Queens	11354	Lead	6/5/2015	6/22/2015	8	0.110
AL-49606	15123220	697EPA274		Brooklyn	11215	Lead	6/8/2015	6/22/2015	5	0.124
AL-49607	15123221	94L0038		Queens	11361	Lead	6/5/2015	6/15/2015	2	0.169
AL-49608	15123222	97AEPA136		New York	10010	Copper / Pb solder	6/4/2015	6/19/2015	0	0.116
AL-49609	15123223	997EPA067		Staten Island	10308	Copper / Pb solder	6/9/2015	7/1/2015	2	0.166
AL-49610	15123224	997EPA146		Staten Island	10306	Copper / Pb solder	6/4/2015	6/15/2015	0	0.156
AL-49611	15123225	997EPA483		Brooklyn	11224	Copper / Pb solder	6/6/2015	6/19/2015	0	0.090
AL-49612	15123226	997EPA553		Bronx	10457	Copper / Pb solder	6/4/2015	6/19/2015	0	0.082
AL-49613	15123227	EPA050018		Brooklyn	11230	Lead	6/4/2015	7/6/2015	11	0.221
AL-49614	15123228	EPA050024		Queens	11415	Copper / Pb solder	6/30/2015	7/15/2015	1	0.104
AL-49615	15123229	EPA050035		Staten Island	10314	Copper / Pb solder	6/6/2015	6/15/2015	0	0.133
AL-49616	15123230	EPA050056		Queens	11433	Lead	6/5/2015	6/19/2015	0	0.198
AL-49617	15123231	EPA050068		Queens	11415	Lead	6/12/2015	6/29/2015	0	0.049
AL-49618	15123232	EPA050069		Queens	11411	Lead	6/25/2015	8/3/2015	6	0.166
AL-49619	15123233	EPA050085		Queens	11433	Copper / Pb solder	6/11/2015	7/1/2015	0	0.146
AL-49620	15123234	EPA060001		Staten Island	10303	Copper / Pb solder	6/5/2015	6/15/2015	0	0.146
AL-49621	15123235	EPA060009		Queens	11412	Lead	6/18/2015	7/14/2015	0	0.040
AL-49622	15123236	EPA060025		Queens	11434	Lead	6/5/2015	6/22/2015	1	0.120
AL-49623	15123237	EPA060039		Bronx	10457	Copper / Pb solder	6/8/2015	6/22/2015	0	0.081
AL-49624	15123238	EPA060041		Brooklyn	11212	Copper / Pb solder	6/6/2015	6/22/2015	0	0.120
AL-49625	15123239	EPA060067		Queens	11418	Lead	7/6/2015	7/29/2015	110	0.183
AL-49626	15123240	EPA060071		Queens	11412	Lead	6/15/2015	7/1/2015	2	0.130
AL-49627	15123241	EPA060079		Queens	11415	Lead	6/8/2015	6/24/2015	2	0.131
AL-49628	15123242	EPA060085		Queens	11432	Lead	6/9/2015	6/24/2015	16	0.169
AL-49629	15123243	EPA070001		Queens	11432	Lead	6/5/2015	6/19/2015	1	0.099
AL-49630	15123244	EPA070012		Queens	11414	Copper / Pb solder	6/7/2015	6/29/2015	0	0.129
AL-49631	15123245	EPA070025		Queens	11420	Lead	6/7/2015	6/29/2015	0	0.143
AL-49632	15123246	EPA070027		Queens	11417	Lead	6/5/2015	6/19/2015	2	0.133
AL-49633	15123247	EPA070031		Staten Island	10307	Copper / Pb solder	6/11/2015	7/1/2015	0	0.172
AL-49634	15123248	EPA070042		Queens	11435	Lead	6/8/2015	7/1/2015	3	0.157
AL-49635	15123249	EPA080012		Queens	11419	Lead	6/6/2015	7/1/2015	0	0.012
AL-49638	15123252	EPA090001		Brooklyn	11224	Copper / Pb solder	7/15/2015	7/29/2015	0	0.109

\*Lead = lead service line

Copper / Pb solder = copper pipes joined by lead solder installed after 1982

° See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/13/2015

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2015 and the monitoring period of June - September 2015**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-49639	15123253	EPA090003		Brooklyn	11212	Copper / Pb solder	6/5/2015	6/22/2015	7	0.206
AL-49640	15123254	EPA090004		Brooklyn	11213	Copper / Pb solder	6/10/2015	6/29/2015	3	0.088
AL-49641	15123255	EPA090008		Staten Island	10301	Lead	6/11/2015	7/6/2015	32	0.343
AL-49642	15123256	EPA090011		Queens	11363	Lead	6/4/2015	6/19/2015	0	0.184
AL-49643	15123257	EPA090013		Bronx	10457	Lead	6/5/2015	6/29/2015	4	0.102
AL-49644	15123258	EPA090023		Bronx	10470	Lead	6/24/2015	7/15/2015	5	0.115
AL-49647	15123261	EPA090035		Queens	11423	Lead	6/4/2015	6/22/2015	1	0.265
AL-49648	15123262	EPA090043		Queens	11102	Lead	6/8/2015	6/29/2015	6	0.089
AL-49649	15123263	EPA090044		Brooklyn	11234	Copper / Pb solder	6/16/2015	7/1/2015	0	0.207
AL-49650	15123264	EPA090045		Queens	11419	Lead	6/5/2015	6/22/2015	3	0.101
AL-50069	15123549	EPA090045		Queens	11419	Lead	6/5/2015	6/22/2015	0	0.141
AL-49651	15123265	EPA100003		Bronx	10461	Lead	6/5/2015	6/22/2015	4	0.145
AL-49652	15123266	EPA100004		Brooklyn	11201	Lead	6/7/2015	6/24/2015	2	0.124
AL-49653	15123267	EPA100005		Queens	11418	Lead	6/5/2015	6/22/2015	2	0.009
AL-49654	15123268	EPA100006		Queens	11419	Lead	6/19/2015	7/14/2015	3	0.110
AL-49655	15123269	EPA100008		Brooklyn	11234	Lead	6/9/2015	6/29/2015	1	0.108
AL-49657	15123271	EPA100012		Queens	11354	Lead	6/10/2015	6/29/2015	10	0.139
AL-49658	15123272	EPA110007		Brooklyn	11205	Lead	6/25/2015	7/15/2015	2	0.208
AL-49660	15123274	EPA110010		Queens	11377	Lead	6/6/2015	6/22/2015	5	0.173
AL-49661	15123275	EPA110013		Brooklyn	11228	Lead	6/4/2015	6/15/2015	18	0.132
AL-49662	15123276	EPA110015		Staten Island	10301	Lead	6/5/2015	6/15/2015	12	0.122
AL-49663	15123277	EPA110017		Queens	11001	Lead	8/1/2015	8/19/2015	4	0.152
AL-49665	15123279	EPA110023		Brooklyn	11234	Lead	6/15/2015	7/1/2015	3	0.003
AL-49667	15123281	EPA110033		Bronx	10464	Lead	6/12/2015	7/1/2015	9	0.149
AL-49669	15123283	EPA110036		Brooklyn	11204	Lead	6/5/2015	6/19/2015	10	0.229
AL-49670	15123284	EPA110038		Bronx	10464	Lead	6/4/2015	6/15/2015	5	0.190
AL-49671	15123285	EPA110039		Queens	11358	Lead	6/6/2015	6/19/2015	6	0.135
AL-49672	15123286	EPA110040		Queens	11375	Lead	8/9/2015	8/25/2015	2	0.113
AL-49673	15123287	EPA110041		Queens	11375	Lead	6/4/2015	6/19/2015	5	0.049
AL-49674	15123288	EPA110042		Queens	11358	Lead	6/14/2015	7/1/2015	14	0.121
AL-49676	15123290	EPA110044		Queens	11361	Lead	6/22/2015	7/14/2015	3	0.210
AL-49677	15123291	EPA110045		Queens	11373	Lead	6/9/2015	7/1/2015	13	0.100

\*Lead = lead service line

Copper / Pb solder = copper pipes joined by lead solder installed after 1982

° See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/13/2015

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2015 and the monitoring period of June - September 2015**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-49679	15123293	EPA110051		Queens	11361	Lead	6/12/2015	7/1/2015	10	0.072
AL-49680	15123294	EPA110053		Queens	11379	Lead	6/4/2015	6/22/2015	9	0.142
AL-49681	15123295	EPA110054		Queens	11432	Lead	6/4/2015	6/19/2015	5	0.148
AL-49682	15123296	EPA110055		Queens	11385	Lead	6/11/2015	7/1/2015	6	0.091
AL-49683	15123297	EPA110056		Queens	11378	Lead	6/10/2015	6/29/2015	10	0.083
AL-49684	15123298	EPA110057		Queens	11358	Lead	6/9/2015	6/24/2015	25	0.133
AL-49685	15123299	EPA110058		Queens	11379	Lead	6/3/2015	6/24/2015	3	0.052
AL-49686	15123300	EPA110059		Queens	11354	Lead	6/7/2015	6/24/2015	5	0.201
AL-49687	15123301	EPA110060		Queens	11361	Lead	6/26/2015	7/15/2015	4	0.092
AL-49688	15123302	EPA110061		Staten Island	10314	Lead	6/10/2015	6/29/2015	3	0.138
AL-49689	15123303	EPA110062		Queens	11375	Lead	6/8/2015	6/24/2015	6	0.103
AL-49690	15123304	EPA110064		Queens	11358	Lead	6/10/2015	6/29/2015	6	0.118
AL-49691	15123305	EPA110065		Queens	11354	Lead	6/14/2015	7/1/2015	1	0.239
AL-49692	15123306	EPA110067		Queens	11432	Lead	6/8/2015	6/29/2015	2	0.044
AL-49693	15123307	EPA110069		Queens	11358	Lead	6/30/2015	7/15/2015	7	0.093
AL-49694	15123308	EPA110070		Queens	11354	Lead	6/12/2015	7/1/2015	3	0.110
AL-49695	15123309	EPA110073		Queens	11358	Lead	6/7/2015	6/22/2015	2	0.099
AL-49696	15123310	EPA110074		Queens	11354	Lead	6/22/2015	7/15/2015	3	0.150
AL-49697	15123311	EPA110075		Queens	11426	Lead	6/8/2015	6/19/2015	2	0.116
AL-49698	15123312	EPA110077		Queens	11378	Lead	6/4/2015	6/15/2015	6	0.088
AL-49699	15123313	EPA110078		Queens	11363	Lead	6/12/2015	7/1/2015	8	0.103
AL-51105	15123551	EPA110079		Queens	11362	Lead	8/8/2015	8/20/2015	3	0.182
AL-49701	15123315	EPA110080		Queens	11432	Lead	6/4/2015	6/19/2015	0	0.050
AL-49702	15123316	EPA110081		Queens	11385	Lead	6/11/2015	7/1/2015	7	0.134
AL-49704	15123318	EPA110088		Staten Island	10304	Lead	7/17/2015	7/29/2015	7	0.112
AL-49705	15123319	EPA110089		Queens	11358	Lead	6/7/2015	6/22/2015	3	0.197
AL-49707	15123321	EPA110091		Queens	11378	Lead	6/4/2015	6/22/2015	4	0.125
AL-49708	15123322	EPA110092		Queens	11385	Lead	7/31/2015	8/19/2015	3	0.051
AL-49710	15123324	EPA110094		Queens	11691	Copper / Pb solder	6/20/2015	7/14/2015	0	0.042
AL-49713	15123327	EPA110097		Brooklyn	11224	Copper / Pb solder	6/6/2015	6/19/2015	0	0.126
AL-49714	15123328	EPA110101		Brooklyn	11207	Copper / Pb solder	6/8/2015	6/29/2015	0	0.110
AL-49715	15123329	EPA110103		Brooklyn	11223	Lead	6/12/2015	7/1/2015	4	0.088

\*Lead = lead service line

Copper / Pb solder = copper pipes joined by lead solder installed after 1982

° See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/13/2015

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2015 and the monitoring period of June - September 2015**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-49716	15123330	EPA110104		Queens	11385	Lead	6/22/2015	7/14/2015	6	0.067
AL-49717	15123331	EPA110105		Queens	11375	Lead	6/5/2015	6/19/2015	5	0.064
AL-49718	15123332	EPA110106		Brooklyn	11234	Lead	6/22/2015	7/15/2015	6	0.153
AL-49719	15123333	EPA110108		Queens	11691	Lead	6/5/2015	6/19/2015	0	0.230
AL-49720	15123334	EPA110109		Queens	11369	Lead	6/9/2015	6/29/2015	6	0.183
AL-49721	15123335	EPA110111		Queens	11354	Lead	6/4/2015	6/15/2015	4	0.087
AL-49722	15123336	EPA110112		Brooklyn	11212	Copper / Pb solder	6/7/2015	6/29/2015	0	0.054
AL-49723	15123337	EPA110113		Brooklyn	11210	Lead	6/18/2015	7/14/2015	5	0.115
AL-49724	15123338	EPA110114		Brooklyn	11224	Copper / Pb solder	7/1/2015	7/29/2015	0	0.062
AL-49725	15123339	EPA110117		Queens	11357	Lead	6/5/2015	6/19/2015	12	0.121
AL-49727	15123341	EPA110124		Staten Island	10308	Copper / Pb solder	6/15/2015	7/1/2015	0	0.034
AL-49728	15123342	EPA110125		Staten Island	10306	Copper / Pb solder	6/8/2015	6/22/2015	0	0.130
AL-49729	15123343	EPA110126		Brooklyn	11212	Copper / Pb solder	6/8/2015	7/1/2015	1	0.148
AL-49730	15123344	EPA110128		Queens	11691	Copper / Pb solder	6/5/2015	6/22/2015	2	0.176
AL-49731	15123345	EPA110129		Staten Island	10309	Copper / Pb solder	6/6/2015	6/19/2015	0	0.104
AL-49732	15123346	EPA110130		Staten Island	10308	Copper / Pb solder	6/5/2015	6/15/2015	2	0.184
AL-49733	15123347	EPA110131		Staten Island	10306	Copper / Pb solder	6/6/2015	6/22/2015	2	0.105
AL-49734	15123348	EPA110132		Staten Island	10306	Copper / Pb solder	6/9/2015	6/29/2015	1	0.210
AL-49735	15123349	EPA110133		Staten Island	10312	Copper / Pb solder	6/6/2015	6/19/2015	1	0.041
AL-49736	15123350	EPA110134		Staten Island	10312	Copper / Pb solder	6/4/2015	6/19/2015	0	0.129
AL-49737	15123351	EPA110135		Staten Island	10314	Copper / Pb solder	6/14/2015	7/1/2015	0	0.043
AL-49738	15123352	EPA110136		Staten Island	10309	Copper / Pb solder	6/10/2015	6/29/2015	0	0.116
AL-49739	15123353	EPA110138		Staten Island	10312	Copper / Pb solder	6/7/2015	6/29/2015	0	0.188
AL-49740	15123354	EPA110139		Staten Island	10306	Copper / Pb solder	6/15/2015	7/1/2015	0	0.122
AL-49741	15123355	EPA110141		Staten Island	10304	Copper / Pb solder	6/5/2015	6/19/2015	1	0.163
AL-49742	15123356	EPA110142		Staten Island	10308	Copper / Pb solder	6/5/2015	6/22/2015	0	0.083
AL-49743	15123357	EPA110143		Staten Island	10306	Copper / Pb solder	6/5/2015	6/19/2015	2	0.158
AL-49744	15123358	EPA110144		Staten Island	10306	Copper / Pb solder	6/8/2015	6/29/2015	3	0.150
AL-49745	15123359	EPA110145		Staten Island	10312	Copper / Pb solder	6/5/2015	6/22/2015	24	0.120
AL-49746	15123360	EPA110146		Staten Island	10308	Copper / Pb solder	6/6/2015	6/29/2015	1	0.111
AL-49747	15123361	EPA110147		Staten Island	10308	Copper / Pb solder	6/10/2015	6/29/2015	2	0.104
AL-49748	15123362	EPA110149		Staten Island	10306	Copper / Pb solder	6/9/2015	6/29/2015	0	0.141

\*Lead = lead service line

Copper / Pb solder = copper pipes joined by lead solder installed after 1982

<sup>o</sup> See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/13/2015

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2015 and the monitoring period of June - September 2015**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-49749	15123363	EPA110150		Staten Island	10306	Copper / Pb solder	6/4/2015	6/19/2015	0	0.159
AL-49750	15123364	EPA110151		Staten Island	10305	Copper / Pb solder	6/4/2015	6/19/2015	0	0.115
AL-49751	15123365	EPA110152		Staten Island	10303	Copper / Pb solder	6/5/2015	6/19/2015	15	0.193
AL-49752	15123366	EPA110153		Staten Island	10314	Copper / Pb solder	6/6/2015	6/24/2015	0	0.146
AL-49753	15123367	EPA110154		Staten Island	10314	Copper / Pb solder	6/22/2015	7/14/2015	0	0.142
AL-49754	15123368	EPA110155		Staten Island	10312	Copper / Pb solder	6/13/2015	7/1/2015	0	0.097
AL-49755	15123369	EPA110156		Staten Island	10312	Copper / Pb solder	6/6/2015	6/29/2015	0	0.140
AL-49756	15123370	EPA110157		Staten Island	10312	Copper / Pb solder	6/19/2015	7/14/2015	46	0.092
AL-49757	15123371	EPA110158		Staten Island	10307	Copper / Pb solder	6/10/2015	6/29/2015	0	0.194
AL-49758	15123372	EPA110159		Staten Island	10309	Copper / Pb solder	6/5/2015	6/19/2015	2	0.147
AL-49760	15123374	EPA110162		Staten Island	10308	Copper / Pb solder	6/5/2015	6/19/2015	1	0.133
AL-49761	15123375	EPA110164		Staten Island	10304	Copper / Pb solder	6/5/2015	6/19/2015	21	0.091
AL-49762	15123376	EPA110165		Staten Island	10314	Copper / Pb solder	6/4/2015	6/19/2015	4	0.132
AL-49764	15123378	EPA110168		Staten Island	10306	Copper / Pb solder	7/2/2015	7/29/2015	3	0.109
AL-49765	15123379	EPA110169		Staten Island	10306	Copper / Pb solder	6/5/2015	6/19/2015	0	0.155
AL-49766	15123380	EPA110170		Staten Island	10309	Copper / Pb solder	6/8/2015	6/29/2015	6	0.092
AL-49767	15123381	EPA110171		Staten Island	10314	Copper / Pb solder	6/4/2015	6/19/2015	0	0.135
AL-49768	15123382	EPA110172		Staten Island	10314	Copper / Pb solder	8/18/2015	9/17/2015	6	0.115
AL-49770	15123384	EPA110174		Staten Island	10309	Copper / Pb solder	8/12/2015	8/24/2015	6	0.095
AL-49771	15123385	EPA110176		Staten Island	10309	Copper / Pb solder	6/8/2015	6/29/2015	2	0.078
AL-49772	15123386	EPA110179		Staten Island	10314	Copper / Pb solder	6/16/2015	7/14/2015	0	0.279
AL-49773	15123387	EPA110183		Staten Island	10306	Copper / Pb solder	6/16/2015	7/14/2015	0	0.062
AL-49774	15123388	EPA110184		Staten Island	10307	Copper / Pb solder	6/8/2015	6/24/2015	1	0.131
AL-49775	15123389	EPA110185		Staten Island	10304	Copper / Pb solder	6/4/2015	6/15/2015	3	0.099
AL-49776	15123390	EPA110187		Staten Island	10305	Copper / Pb solder	8/13/2015	8/25/2015	0	0.158
AL-49777	15123391	EPA110188		Staten Island	10304	Copper / Pb solder	6/25/2015	7/15/2015	0	0.080
AL-49778	15123392	EPA110189		Staten Island	10314	Copper / Pb solder	6/10/2015	7/1/2015	0	0.129
AL-49779	15123393	EPA110190		Staten Island	10314	Copper / Pb solder	6/4/2015	6/19/2015	0	0.161
AL-49780	15123394	EPA110191		Staten Island	10309	Copper / Pb solder	6/8/2015	7/1/2015	0	0.184
AL-49781	15123395	EPA110192		Staten Island	10308	Copper / Pb solder	6/6/2015	7/1/2015	0	0.024
AL-49782	15123396	EPA110194		Queens	11379	Lead	6/9/2015	6/29/2015	4	0.128
AL-49784	15123398	EPA110198		Bronx	10465	Lead	6/8/2015	6/22/2015	4	0.190

\*Lead = lead service line

Copper / Pb solder = copper pipes joined by lead solder installed after 1982

<sup>o</sup> See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/13/2015

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2015 and the monitoring period of June - September 2015**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-49785	15123399	EPA110199		Brooklyn	11218	Lead	6/19/2015	7/1/2015	12	0.118
AL-49786	15123400	EPA110200		Queens	11360	Copper / Pb solder	6/9/2015	7/1/2015	0	0.125
AL-49787	15123401	EPA120002		Staten Island	10305	Copper / Pb solder	6/19/2015	7/14/2015	0	0.083
AL-49788	15123402	EPA120003		Staten Island	10305	Copper / Pb solder	6/9/2015	6/29/2015	6	0.123
AL-49789	15123403	EPA120004		Staten Island	10309	Copper / Pb solder	6/3/2015	6/15/2015	0	0.126
AL-49790	15123404	EPA120006		Queens	11385	Lead	6/20/2015	7/15/2015	12	0.135
AL-49791	15123405	EPA120007		Staten Island	10303	Copper / Pb solder	6/11/2015	7/1/2015	3	0.258
AL-49792	15123406	EPA120008		Staten Island	10309	Copper / Pb solder	6/4/2015	6/22/2015	0	0.138
AL-49794	15123408	EPA120010		Staten Island	10312	Copper / Pb solder	6/7/2015	6/24/2015	0	0.106
AL-49795	15123409	EPA120012		Queens	11105	Lead	6/5/2015	6/19/2015	11	0.134
AL-49796	15123410	EPA120014		Brooklyn	11212	Copper / Pb solder	6/6/2015	6/15/2015	0	0.097
AL-49797	15123411	EPA120015		Staten Island	10306	Copper / Pb solder	6/23/2015	7/14/2015	10	0.115
AL-49798	15123412	EPA120017		Brooklyn	11223	Lead	6/10/2015	6/29/2015	12	0.050
AL-49800	15123414	EPA120021		Staten Island	10305	Copper / Pb solder	6/14/2015	7/14/2015	0	0.134
AL-49801	15123415	EPA120026		Staten Island	10312	Copper / Pb solder	6/17/2015	7/1/2015	0	0.035
AL-49802	15123416	EPA120028		Staten Island	10309	Copper / Pb solder	6/6/2015	6/19/2015	0	0.066
AL-51104	15123550	EPA120029		Staten Island	10308	Copper / Pb solder	8/10/2015	8/20/2015	5	0.101
AL-49805	15123419	EPA120033		Staten Island	10309	Copper / Pb solder	6/5/2015	6/19/2015	3	0.163
AL-49806	15123420	EPA130001		Queens	11375	Lead	6/4/2015	7/6/2015	2	0.057
AL-49807	15123421	EPA130002		Staten Island	10308	Copper / Pb Solder	7/9/2015	7/29/2015	1	0.136
AL-49810	15123424	EPA140002		Staten Island	10310	Copper / Pb Solder	6/5/2015	6/15/2015	1	0.167
AL-49811	15123425	EPA140003		Queens	11412	Lead	6/27/2015	7/15/2015	2	0.091
AL-49813	15123427	EPA140006		Queens	11418	Lead	6/9/2015	6/29/2015	1	0.287
AL-49814	15123428	EPA140007		Brooklyn	11215	Lead	6/17/2015	7/15/2015	35	0.152
AL-49816	15123430	EPA140009		Queens	11361	Lead	6/15/2015	7/1/2015	2	0.050
AL-49819	15123433	EPA150001		Brooklyn	11228	Lead	6/4/2015	6/15/2015	12	0.262
AL-49820	15123434	EPA150002		Queens	11421	Lead	6/6/2015	6/24/2015	0	0.081
AL-49821	15123435	EPA150003		Brooklyn	11224	Lead	6/5/2015	6/19/2015	6	0.206
AL-49823	15123437	EPA150005		Brooklyn	11215	Lead	6/11/2015	7/1/2015	4	0.122
AL-49824	15123438	EPA150006		Brooklyn	11215	Lead	6/4/2015	6/19/2015	4	0.154
AL-50847	151365	EPA150007		Staten Island	10309	Copper / Pb solder	8/10/2015	8/24/2015	0	0.101
AL-49825	15123439	EPA150008		Queens	11691	Lead	6/4/2015	6/15/2015	16	0.485

\*Lead = lead service line

Copper / Pb solder = copper pipes joined by lead solder installed after 1982

° See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/13/2015

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2015 and the monitoring period of June - September 2015**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-49828	15123442	EPA150011		Bronx	10471	Lead	7/16/2015	8/19/2015	13	0.285
AL-49829	15123443	EPA150012		Queens	11375	Lead	6/13/2015	7/1/2015	9	0.159
AL-49830	15123444	EPA150013		Queens	11105	Lead	6/8/2015	6/22/2015	1	0.140
AL-49831	15123445	EPA150014		Queens	11417	Lead	6/9/2015	6/24/2015	2	0.163
AL-49832	15123446	EPA150015		Queens	11385	Lead	6/11/2015	7/1/2015	3	0.161
AL-49834	15123448	EPA150017		Brooklyn	11234	Lead	6/23/2015	7/15/2015	13	0.125
AL-49835	15123449	EPA150018		Queens	11358	Lead	6/6/2015	6/24/2015	4	0.133
AL-49836	15123450	EPA150020		Queens	11358	Lead	6/20/2015	7/14/2015	2	0.120
AL-49837	15123451	EPA150021		Queens	11375	Lead	6/16/2015	7/1/2015	7	0.157
AL-49838	15123452	EPA150022		Queens	11358	Lead	6/23/2015	7/15/2015	5	0.121
AL-49839	15123453	EPA150023		Queens	11385	Lead	6/6/2015	6/29/2015	10	0.192
AL-49840	15123454	EPA150024		Bronx	10464	Lead	6/7/2015	6/24/2015	4	0.180
AL-49841	15123455	EPA150025		Queens	11377	Lead	6/11/2015	6/29/2015	1	0.065
AL-49842	15123456	EPA150026		Queens	11377	Lead	6/5/2015	6/15/2015	6	0.125
AL-49843	15123457	EPA150027		Staten Island	10304	Lead	6/10/2015	7/1/2015	5	0.118
AL-49844	15123458	EPA150028		Brooklyn	11229	Lead	6/7/2015	6/29/2015	6	0.086
AL-49846	15123460	EPA150030		Staten Island	10305	Lead	6/13/2015	7/1/2015	89	0.134
AL-49847	15123461	EPA150031		Queens	11375	Lead	6/4/2015	6/22/2015	5	0.096
AL-49848	15123462	EPA150032		Brooklyn	11229	Lead	6/8/2015	6/22/2015	9	0.104
AL-50849	151367	EPA150034		Staten Island	10308	Copper / Pb solder	8/12/2015	8/25/2015	2	0.078
AL-49850	15123464	EPA150035		Brooklyn	11217	Lead	6/5/2015	6/22/2015	0	0.048
AL-49851	15123465	EPA150036		Staten Island	10310	Copper / Pb solder	6/6/2015	6/22/2015	1	0.190
AL-49852	15123466	EPA150037		Brooklyn	11215	Lead	6/8/2015	6/29/2015	3	0.155
AL-49853	15123467	EPA150038		Manhattan	10128	Lead	6/5/2015	6/19/2015	5	0.094
AL-49854	15123468	EPA150039		Staten Island	10308	Copper / Pb solder	6/7/2015	6/22/2015	2	0.146
AL-49856	15123470	EPA150041		Bronx	10463	Lead	6/26/2015	7/15/2015	1	0.122
AL-49857	15123471	EPA150042		Queens	11372	Lead	6/8/2015	7/1/2015	7	0.155
AL-49858	15123472	EPA150043		Brooklyn	11234	Lead	6/9/2015	6/29/2015	6	0.128
AL-49859	15123473	EPA150044		Staten Island	10310	Lead	6/6/2015	6/22/2015	5	0.166
AL-49860	15123474	EPA150045		Brooklyn	11230	Lead	6/17/2015	7/1/2015	9	0.147
AL-49861	15123475	EPA150046		Brooklyn	11213	Copper / Pb solder	6/5/2015	6/29/2015	2	0.232
AL-49862	15123476	EPA150047		Brooklyn	11208	Lead	6/5/2015	6/19/2015	0	0.136

\*Lead = lead service line

Copper / Pb solder = copper pipes joined by lead solder installed after 1982

° See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/13/2015

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2015 and the monitoring period of June - September 2015**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-49863	15123477	EPA150048		Queens	NULL	Copper / Pb solder	7/1/2015	7/15/2015	0	0.253
AL-49864	15123478	EPA150049		Queens	NULL	Lead	6/28/2015	7/29/2015	4	0.137
AL-49865	15123479	EPA150050		Queens	11354	Lead	6/8/2015	6/24/2015	4	0.169
AL-49866	15123480	EPA150051		Queens	11413	Lead	7/14/2015	8/19/2015	0	0.106
AL-49867	15123481	EPA150052		Queens	11412	Lead	6/5/2015	6/19/2015	40	0.262
AL-49868	15123482	EPA150053		Queens	11421	Lead	6/19/2015	7/14/2015	9	0.175
AL-49869	15123483	EPA150054		Queens	11379	Lead	7/2/2015	7/29/2015	7	0.121
AL-49870	15123484	EPA150055		Queens	11358	Lead	6/25/2015	7/15/2015	2	0.245
AL-49872	15123486	EPA150057		Queens	11413.0	Lead	9/27/2015	10/1/2015	6	0.089
AL-49873	15123487	EPA150058		Queens	11379	Lead	6/4/2015	6/22/2015	4	0.116
AL-49874	15123488	EPA150059		Brooklyn	11225	Lead	6/9/2015	6/29/2015	4	0.057
AL-49875	15123489	EPA150060		Brooklyn	11209	Lead	8/15/2015	8/24/2015	5	0.172
AL-50850	151368	EPA150061		Staten Island	10306	Copper / Pb solder	8/13/2015	8/24/2015	0	0.098
AL-49876	15123490	EPA150062		Brooklyn	11204	Lead	6/5/2015	6/22/2015	8	0.119
AL-49878	15123492	EPA150064		Queens	11361	Lead	6/15/2015	7/1/2015	1	0.185
AL-49879	15123493	EPA150065		Queens	11427	Lead	6/4/2015	6/15/2015	5	0.121
AL-49880	15123494	EPA150066		Brooklyn	11226	Lead	6/11/2015	7/1/2015	5	0.119
AL-49882	15123496	EPA150068		Brooklyn	11225	Lead	6/4/2015	6/19/2015	30	0.189
AL-49883	15123497	EPA150069		Brooklyn	11220	Lead	6/22/2015	7/14/2015	1	0.153
AL-49884	15123498	EPA150070		Brooklyn	11210	Lead	7/5/2015	7/29/2015	2	0.348
AL-49885	15123499	EPA150071		Queens	11101	Lead	6/10/2015	6/24/2015	5	0.089
AL-49886	15123500	EPA150072		Queens	11101	Lead	6/7/2015	6/24/2015	2	0.275
AL-49888	15123502	EPA150074		Queens	11375	Lead	6/12/2015	7/1/2015	11	0.151
AL-49889	15123503	EPA150075		Queens	11432	Lead	6/4/2015	6/19/2015	52	0.135
AL-50068	15123548	EPA150075		Queens	11432	Lead	6/4/2015	6/15/2015	2	0.019
AL-50851	151369	EPA150076		Staten Island	10306	Copper / Pb solder	8/12/2015	8/24/2015	7	0.122
AL-49890	15123504	EPA150077		Staten Island	10309	Copper / Pb solder	6/6/2015	6/24/2015	1	0.144
AL-49891	15123505	EPA150078		Brooklyn	11221	Lead	6/23/2015	7/15/2015	8	0.157
AL-49892	15123506	EPA150079		Brooklyn	11214	Lead	6/4/2015	6/22/2015	9	0.133
AL-49893	15123507	EPA150080		Brooklyn	11228	Lead	7/9/2015	7/29/2015	15	0.105
AL-49894	15123508	EPA150081		Queens	11106	Lead	6/26/2015	7/15/2015	6	0.124
AL-49895	15123509	EPA150082		Queens	11416	Lead	6/26/2015	7/15/2015	2	0.151
AL-49896	15123510	EPA150083		Brooklyn	11214	Lead	6/4/2015	6/22/2015	3	0.152

\*Lead = lead service line

Copper / Pb solder = copper pipes joined by lead solder installed after 1982

° See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/13/2015



**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2015 and the monitoring period of June - September 2015**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-49897	15123511	EPA150084		Brooklyn	11228	Lead	6/4/2015	6/22/2015	5	0.050
AL-50853	151371	EPA150086		Staten Island	10312	Copper / Pb solder	8/11/2015	8/20/2015	6	0.071
AL-50854	151372	EPA150087		Staten Island	10309	Copper / Pb solder	8/10/2015	8/20/2015	0	0.116
AL-50855	151373	EPA150088		Staten Island	10306	Copper / Pb solder	8/12/2015	8/24/2015	2	0.130
AL-50856	151374	EPA150089		Staten Island	10308	Copper / Pb solder	8/26/2015	9/17/2015	0	0.115
AL-50857	151375	EPA150090		Staten Island	10306	Copper / Pb solder	9/6/2015	9/25/2015	0	0.081
AL-50858	151376	EPA150091		Staten Island	10309	Copper / Pb solder	8/11/2015	8/24/2015	5	0.105
AL-50859	151377	EPA150092		Staten Island	10308	Copper / Pb solder	8/15/2015	8/25/2015	15	0.148
AL-50860	151378	EPA150093		Staten Island	10309	Copper / Pb solder	8/10/2015	8/24/2015	0	0.052
AL-50861	151379	EPA150094		Staten Island	10309	Copper / Pb solder	8/15/2015	8/24/2015	0	0.061
AL-50862	151380	EPA150095		Staten Island	10309	Copper / Pb solder	8/11/2015	8/24/2015	0	0.124
AL-50863	151381	EPA150096		Staten Island	10309	Copper / Pb solder	8/15/2015	8/25/2015	0	0.179
AL-50864	151382	EPA150097		Staten Island	10306	Copper / Pb solder	8/13/2015	8/24/2015	14	0.158
AL-50865	151383	EPA150098		Brooklyn	11212	Copper / Pb solder	8/29/2015	9/17/2015	0	0.108
AL-50866	151384	EPA150099		Brooklyn	11212	Copper / Pb solder	8/12/2015	8/24/2015	1	0.160
AL-50867	151385	EPA150100		Brooklyn	11212	Copper / Pb solder	8/14/2015	8/24/2015	0	0.145
AL-50868	151386	EPA150101		Staten Island	10309	Copper / Pb solder	9/2/2015	9/17/2015	0	0.126
AL-50869	151387	EPA150103		Staten Island	10308	Copper / Pb solder	8/11/2015	8/20/2015	0	0.067
AL-50870	151388	EPA150104		Staten Island	10309	Copper / Pb solder	8/12/2015	8/24/2015	0	0.067
AL-50871	151389	EPA150105		Staten Island	10308	Copper / Pb solder	8/13/2015	8/24/2015	0	0.088
AL-50872	151390	EPA150106		Staten Island	10306	Copper / Pb solder	8/11/2015	8/20/2015	2	0.097
AL-50873	151391	EPA150107		Staten Island	10305	Copper / Pb solder	8/11/2015	8/24/2015	0	0.092
AL-49899	15123513	EPA150110		Queens	11385	Lead	6/7/2015	6/22/2015	16	0.057
AL-50876	151394	EPA150111		Staten Island	10309	Copper / Pb solder	8/9/2015	8/20/2015	2	0.080
AL-50877	151395	EPA150112		Staten Island	10309	Copper / Pb solder	8/17/2015	8/25/2015	0	0.065
AL-50878	151396	EPA150113		Staten Island	10312	Copper / Pb solder	8/11/2015	8/24/2015	2	0.113
AL-50879	151397	EPA150114		Staten Island	10309.0	Copper / Pb solder	9/28/2015	9/29/2015	0	0.145
AL-50880	151398	EPA150115		Staten Island	10306	Copper / Pb solder	8/10/2015	8/20/2015	45	0.061
AL-50881	151399	EPA150116		Staten Island	10306	Copper / Pb solder	8/14/2015	8/25/2015	0	0.121
AL-50882	151400	EPA150117		Staten Island	10309	Copper / Pb solder	8/13/2015	8/24/2015	0	0.083
AL-50883	151401	EPA150118		Staten Island	10309	Copper / Pb solder	8/28/2015	9/17/2015	0	0.131
AL-50884	151402	EPA150120		Staten Island	10312	Copper / Pb solder	8/11/2015	8/24/2015	0	0.089
AL-50885	151403	EPA150121		Staten Island	10306	Copper / Pb solder	9/8/2015	9/25/2015	0	0.178
AL-50887	151405	EPA150123		Staten Island	10312	Copper / Pb solder	8/13/2015	8/24/2015	1	0.118

\*Lead = lead service line

Copper / Pb solder = copper pipes joined by lead solder installed after 1982

° See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/13/2015

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2015 and the monitoring period of June - September 2015**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-50889	151407	EPA150125		Staten Island	10303	Copper / Pb solder	8/10/2015	8/20/2015	0	0.127
AL-49901	15123515	EPA150126		Staten Island	10309	Copper / Pb solder	6/11/2015	7/1/2015	0	0.118
AL-50890	151408	EPA150127		Staten Island	10306.0	Copper / Pb solder	9/20/2015	9/29/2015	1	0.200
AL-50891	151409	EPA150128		Staten Island	10308	Copper / Pb solder	8/15/2015	8/25/2015	0	0.142
AL-50892	151410	EPA150129		Staten Island	10312	Copper / Pb solder	8/18/2015	8/25/2015	4	0.077
AL-50893	151411	EPA150130		Staten Island	10309	Copper / Pb solder	8/28/2015	9/17/2015	0	0.069
AL-50894	151412	EPA150131		Staten Island	10312.0	Copper / Pb solder	9/24/2015	9/28/2015	64	0.127
AL-50895	151413	EPA150132		Staten Island	10312	Copper / Pb solder	8/12/2015	8/20/2015	0	0.073
AL-50896	151414	EPA150133		Staten Island	10312	Copper / Pb solder	8/12/2015	8/24/2015	14	0.066
AL-50897	151415	EPA150134		Staten Island	10309	Copper / Pb solder	8/24/2015	9/17/2015	0	0.078
AL-50898	151416	EPA150135		Staten Island	10309	Copper / Pb solder	8/10/2015	8/20/2015	2	0.051
AL-50899	151417	EPA150136		Staten Island	10312	Copper / Pb solder	8/8/2015	8/24/2015	0	0.060
AL-50900	151418	EPA150137		Brooklyn	11224	Copper / Pb solder	8/12/2015	8/24/2015	0	0.155
AL-50901	151419	EPA150138		Queens	11691	Copper / Pb solder	8/11/2015	8/20/2015	0	0.072
AL-50902	151420	EPA150139		Queens	11413	Copper / Pb solder	9/3/2015	9/17/2015	0	0.050
AL-50903	151421	EPA150140		Staten Island	10309	Copper / Pb solder	8/9/2015	8/24/2015	68	0.090
AL-50904	151422	EPA150141		Staten Island	10309	Copper / Pb solder	8/10/2015	8/20/2015	0	0.101
AL-50905	151423	EPA150142		Staten Island	10309	Copper / Pb solder	9/21/2015	9/22/2015	0	0.057
AL-50906	151424	EPA150143		Staten Island	10309	Copper / Pb solder	8/10/2015	8/20/2015	2	0.086
AL-50907	151425	EPA150144		Staten Island	10306	Copper / Pb solder	9/20/2015	9/24/2015	0	0.187
AL-50908	151426	EPA150145		Staten Island	10314	Copper / Pb solder	8/10/2015	8/20/2015	12	0.083
AL-50909	151427	EPA150146		Staten Island	10306	Copper / Pb solder	8/11/2015	8/20/2015	0	0.158
AL-50910	151428	EPA150147		Staten Island	10312	Copper / Pb solder	8/14/2015	8/24/2015	4	0.103
AL-50911	151429	EPA150148		Staten Island	10314	Copper / Pb solder	8/16/2015	9/17/2015	0	0.093
AL-50912	151430	EPA150149		Staten Island	10301	Copper / Pb solder	8/8/2015	8/20/2015	0	0.038
AL-50913	151431	EPA150150		Staten Island	10306	Copper / Pb solder	9/1/2015	9/17/2015	3	0.133
AL-50914	151432	EPA150151		Staten Island	10305	Copper / Pb solder	9/21/2015	9/25/2015	0	0.126
AL-50916	151434	EPA150153		Staten Island	10308	Copper / Pb solder	8/20/2015	9/17/2015	0	0.072
AL-50917	151435	EPA150154		Staten Island	10308	Copper / Pb solder	8/19/2015	9/17/2015	0	0.116
AL-50918	151436	EPA150155		Staten Island	10314	Copper / Pb solder	8/12/2015	8/24/2015	0	0.116
AL-50919	151437	EPA150156		Staten Island	10309	Copper / Pb solder	8/14/2015	8/24/2015	0	0.097
AL-50920	151438	EPA150157		Staten Island	10309	Copper / Pb solder	8/10/2015	8/20/2015	0	0.058
AL-50923	151441	EPA150160		Staten Island	10312	Copper / Pb solder	8/11/2015	8/24/2015	0	0.065
AL-50924	151442	EPA150161		Staten Island	10304	Copper / Pb solder	9/1/2015	9/17/2015	1	0.095

\*Lead = lead service line

Copper / Pb solder = copper pipes joined by lead solder installed after 1982

° See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/13/2015

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2015 and the monitoring period of June - September 2015**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-50925	151443	EPA150162		Staten Island	10314	Copper / Pb solder	8/13/2015	8/25/2015	69	0.152
AL-50926	151444	EPA150163		Staten Island	10305	Copper / Pb solder	9/8/2015	9/17/2015	2	0.257
AL-50928	151446	EPA150166		Brooklyn	11212	Copper / Pb solder	9/8/2015	9/25/2015	0	0.112
AL-49905	15123519	EPA150167		Queens	11434	Copper / Pb solder	6/4/2015	6/19/2015	5	0.147
AL-50929	151447	EPA150168		Brooklyn	11224	Copper / Pb solder	8/11/2015	8/20/2015	0	0.019
AL-49906	15123520	EPA150188		Staten Island	10312	Copper / Pb solder	6/5/2015	6/19/2015	31	0.074
AL-49909	15123523	EPA150197		Brooklyn	11206	Lead	6/11/2015	7/1/2015	11	0.167
AL-49910	15123524	EPA150198		Manhattan	10018	Lead	6/5/2015	6/22/2015	5	0.194
AL-49911	15123525	EPA150199		Queens	11365	Lead	6/4/2015	6/15/2015	0	0.181
AL-49913	15123527	EPA150203		Brooklyn	11213	Copper / Pb solder	6/9/2015	6/29/2015	6	0.128
AL-49915	15123529	EPA150205		Queens	11694	Copper / Pb solder	6/4/2015	6/29/2015	2	0.148
AL-49919	15123533	EPA943282		Bronx	10471	Copper / Pb solder	6/7/2015	6/29/2015	2	0.150
AL-49920	15123534	EPA943646		Brooklyn	11210	Lead	6/4/2015	6/19/2015	5	0.090
AL-49921	15123535	EPA943711		Brooklyn	11218	Lead	6/6/2015	7/6/2015	18	0.092
AL-49922	15123536	EPA954261		Staten Island	10312	Copper / Pb solder	6/8/2015	6/22/2015	0	0.131
AL-49923	15123537	EPA954389		Staten Island	10309	Copper / Pb solder	6/5/2015	6/29/2015	70	0.779
AL-49924	15123538	EPA955349		Brooklyn	11234	Lead	6/6/2015	6/19/2015	5	0.176
AL-49925	15123539	EPA955507		Queens	11432	Lead	6/7/2015	6/22/2015	4	0.234
AL-49926	15123540	EPA95A585		Brooklyn	11236	Copper / Pb solder	6/9/2015	6/24/2015	0	0.147
AL-49927	15123541	EPA95A648		Brooklyn	11209	Copper / Pb solder	6/25/2015	7/15/2015	0	0.023
AL-49929	15123543	EPA997025		Bronx	10462	Lead	6/12/2015	7/1/2015	20	0.281
AL-49930	15123544	EPA997171		Brooklyn	11234	Lead	6/8/2015	6/24/2015	4	0.137
AL-49931	15123545	EPA997230		Bronx	10463	Lead	6/5/2015	6/19/2015	4	0.054
AL-49932	15123546	EPA997875		Queens	11375	Lead	6/4/2015	6/22/2015	7	0.140
AL-49933	15123547	EPA997885		Brooklyn	11232	Lead	6/4/2015	6/19/2015	5	0.107

\*Lead = lead service line

Copper / Pb solder = copper pipes joined by lead solder installed after 1982

° See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/13/2015